

## **Section 2**

### **LP-Gas Room Heaters.**

#### **§ 9-17-120. Definitions.**

For the purposes of this article, the following words shall have the following meanings:

- (1) **LP-GAS.** Liquefied petroleum gas as defined in Section 9-17-100.
- (2) **USED MANUFACTURED HOME.** A manufactured home which is not being sold or offered for sale as new, and is used for residential purposes. (Acts 1994, No. 94-706, p. 1369, § 1; Acts 1995, No. 95-146, p. 208, § 1.)

#### **§ 9-17-121. Installation of heaters—residences.**

**The following LP-Gas room heaters may be installed in a residence that is a one or two-family dwelling and that is not a manufactured home (mobile home) or a modular home as provided in this section:**

- (1) One listed **wall-mounted** LP-Gas unvented room heater equipped with an oxygen depletion safety shut-off system may be installed in the bathroom of a residential one- or two-family dwelling provided that the input rating shall not exceed 6000 BTU per hour and combustion and ventilation air is provided in accordance with paragraph 6.1(b) of the National Fuel Gas Code, NFPA 54.
- (2) One listed **wall-mounted** LP-Gas unvented room heater equipped with an oxygen depletion safety shut-off system may be installed in the bedroom of a residential one- or two-family dwelling provided that the input rating shall not exceed 10,000 BTU per hour and combustion and ventilation air is provided as specified in paragraph 6.1(b) of the National Fuel Gas Code, NFPA 54. (Acts 1994, No. 94-706, p. 1369, § 2.)

#### **§ 9-17-122. Installation of heaters—used manufactured homes.**

**The following LP-Gas room heaters may be installed in a used manufactured home as follows:**

LP-Gas listed vented room heaters equipped with a 100 percent safety pilot and a vent spill switch or LP-Gas listed unvented room heaters equipped with factory equipped oxygen depletion safety shut-off systems may be installed in a used stationary manufactured home (mobile home) but not in sleeping quarters or bathrooms in the manufactured home (mobile home) when the installation of the heater is not prohibited by the appliance manufacturer and when the input rating of the room heater does not exceed 20 BTU per hour per cubic foot of space and combustion and ventilation air is provided as specified in Section 5.3 of the National Fuel Gas Code, NFPA 54. All room

heaters installed pursuant to this section shall be securely **anchored to the wall or floor.**  
(Acts 1994, No. 94-706, p. 1369, § 3.)

**§ 9-17-123. Enforcement.** This article shall be enforced by the Liquefied Petroleum Gas Board. (Acts 1994, No. 94-706, p. 1369, § 4.)

**§ 9-17-124. Reference to National Fuel Gas Code.** Any reference to the National Fuel Gas Code, NFPA 54, shall include any future changes to the code when adopted by the Liquefied Petroleum Gas Board. (Acts 1994, No. 94-706, p. 1369, § 5.)

**§ 9-17-125. Preemption of local law.** This article shall preempt any local law or any ordinance or authority of any local governing body to regulate the subject matter of this article and no local law or ordinance or authority of any local governing body shall supersede this article. (Acts 1994, No. 94-706, p. 1369, § 6.)